Disclaimer. This documentation is not intended as a substitute for and is not to be used for determining suitability or reliability of these products for specific user applications



enclosed variable speed drive ATV71 Plus - 315 kW - 400 V - IP54

ATV71EXC5C31N4

! Discontinued on: Jul 23, 2021 AD

Main

Range Of Product	Altivar 71 Plus				
Product Or Component Type	Variable speed drive				
Device Short Name	ATV71 Plus				
Product Destination	Asynchronous motors				
	Synchronous motors				
Product Specific Application	Complex, high-power machines				
Assembly Style	In floor-standing enclosure compact version				
Product Composition	An IP65 remote mounting kit for graphic display terminal				
	Terminals/bars for motor connection				
	ATV71HC31N4D drive on heatsink				
	A wired ready-assembled Sarel Spacial 6000 enclosure				
	A switch and fast-acting semi-conductor fuses				
	A line choke				
Emc Filter	Integrated				
Network Number Of Phases	3 phases				
Rated Supply Voltage	380415 V +/- 10 %				
Supply Voltage Limits	342457 V				
Supply Frequency	5060 Hz +/- 5 %				
Network Frequency	47.563 Hz				
Motor Power Kw	315 kW at 380415 V				
Line Current	529 A for 400 V / 315 kW				

Complementary

Apparent Power	365 kVA for 400 V / 315 kW			
Prospective Line Isc	100 kA with external fuses 616 A at 2.5 kHz, 400 V / 315 kW			
Continuous Output Current				
Maximum Transient Current	924 A for 60 s / 315 kW			
Speed Drive Output Frequency	0500 Hz			
Nominal Switching Frequency	2.5 kHz			
Switching Frequency	2.58 kHz with derating factor 28 kHz adjustable			
Speed Range	1100 in open-loop mode, without speed feedback			
Speed Accuracy	+/- 0.01 % of nominal speed in closed-loop mode with encoder feedback 0.2 Tn to Tn +/- 10 % of nominal slip without speed feedback 0.2 Tn to Tn			

Torque Accuracy	+/- 15 % in open-loop mode, without speed feedback +/- 5 % in closed-loop mode with encoder feedback				
	., 5 // in diodod loop mode mai enough tocaback				
Transient Overtorque	170 % of nominal motor torque +/- 10 % for 60 s 220 % of nominal motor torque +/- 10 % for 2 s				
Braking Torque	<= 150 % with braking or hoist resistor 30 % without braking resistor				
Asynchronous Motor Control Profile	Flux vector control with sensor, standard Voltage/frequency ratio, 2 points Flux vector control without sensor, 2 points Voltage/frequency ratio - Energy Saving, quadratic U/f Flux vector control without sensor, ENA (energy Adaptation) system Flux vector control without sensor, standard Voltage/frequency ratio, 5 points				
Synchronous Motor Control Profile	ector control without sensor, standard control with sensor, standard				
Regulation Loop	Adjustable PI regulator				
Motor Slip Compensation	Not available in voltage/frequency ratio (2 or 5 points) Adjustable Suppressable Automatic whatever the load				
Overvoltage Category	Class 3 conforming to EN 50178				
Local Signalling	LCD display unit for operation function, status and configuration - mounted in the front door				
Output Voltage	<= power supply voltage				
Isolation	Electrical between power and control				
Type Of Cable For External Connection	IEC cable at 40 °C, copper 70 °C / PVC				
Electrical Connection	Terminal - 2.5 mm² / AWG 14 (AI1-/AI1+, AI2, AO1, R1A, R1B, R1C, R2A, R2B, LI1LI6, PWR) entry from the bottom Bar M12 - 4 x 300 mm² (L1/R, L2/S, L3/T) entry from the bottom Bar M12 - 4 x 240 mm² (U/T1, V/T2, W/T3) entry from the bottom				
Motor Recommanded Cable Cross Section	3 (3 x 150) mm ²				
Short-Circuit Protection	800 A fuse protection type gI - power supply upstream				
Supply	External supply: 24 V DC (1930 V), <1 A Internal supply for reference potentiometer: 10 V DC (1011 V), <10 mA Internal supply: 24 V DC (2127 V), <100 mA				
Analogue Input Number	2				
Analogue Input Type	Al2 software-configurable voltage: 010 V DC, 24 V max, impedance: 30000 Ohm, sampling time: 1.52.5 ms, resolution: 11 bits Al1-/Al1+ bipolar differential voltage: +/- 10 V DC, 24 V max, sampling time: 1.52.5 ms, resolution: 11 bits + sign Al2 software-configurable current: 020 mA/420 mA, impedance: 250 Ohm, sampling time: 1.52.5 ms, resolution: 11 bits				
Analogue Output Number	1				
Analogue Output Type	Software-configurable voltage: (AO1) 010 V DC - 470 Ohm - sampling time: 1.5. 2.5 ms - resolution: 10 bits Software-configurable current: (AO1) 020 mA/420 mA - 500 Ohm - sampling time: 1.52.5 ms - resolution: 10 bits				
Discrete Output Number	2				
Discrete Output Type	Configurable relay logic: (R1A, R1B, R1C)NO/NC - 6.57.5 ms - 100000 cycles Configurable relay logic: (R2A, R2B)NO - 6.57.5 ms - 100000 cycles				
Minimum Switching Current	3 mA at 24 V DC (configurable relay logic)				
Maximum Switching Current	5 A at 250 V AC on resistive load - cos phi = 1 (R1, R2) 5 A at 30 V DC on resistive load - L/R = 0 ms (R1, R2) 2 A at 250 V AC on inductive load - cos phi = 0.4 (R1, R2) 2 A at 30 V DC on inductive load - L/R = 7 ms (R1, R2)				

Discrete Input Number	7			
Discrete Input Type	Programmable (LI1LI5) at 24 V DC <= 30 V level 1 PLC 3.5 kOhm (duration=1.5			
	2.5 ms) Switch-configurable (LI6) at 24 V DC <= 30 V level 1 PLC 1.5 kOhm (duration=1.5			
	2.5 ms) Safety input (PWR) at 24 V DC <= 30 V 1.5 kOhm			
Discrete Input Logic	Positive logic (source) (Ll1Ll6), 05 V (state 0), 1130 V (state 1)			
noorete input Legie	Negative logic (sink) (LI1LI6), 1630 V (state 0), 010 V (state 1)			
	Positive logic (source) (PWR), 02 V (state 0), 1730 V (state 1)			
Acceleration And Deceleration	Linear adjustable separately from 0.01 to 9000 s			
Ramps	S, U or customized Automatic adaptation of ramp if braking capacity exceeded, by using resistor			
Braking To Standstill	By DC injection			
Protection Type	Against exceeding limit speed: drive			
Troteodion Type	Against exceeding infilt speed, drive Against input phase loss: drive			
	Break on the control circuit: drive			
	Input phase breaks: drive			
	Line supply overvoltage: drive			
	Line supply undervoltage: drive			
	Overcurrent between output phases and earth: drive			
	Overheating protection: drive			
	Overvoltages on the DC bus: drive			
	Short-circuit between motor phases: drive			
	Thermal protection: drive			
	Input phase breaks: motor			
	Power removal: motor Thermal protection: motor			
Dielectric Strength	3535 V DC between earth and power terminals			
2.0.00a.10 0a.0.1ga.	5092 V DC between control and power terminals			
Insulation Resistance	> 1 mOhm 500 V DC for 1 minute to earth			
Frequency Resolution	Analog input: 0.024/50 Hz			
	Display unit: 0.1 Hz			
Communication Port Protocol	Modbus CANopen			
Connector Type	1 RJ45 (on front face) for Modbus			
	1 RJ45 (on terminal) for Modbus			
	Male SUB-D 9 on RJ45 for CANopen			
Physical Interface	2-wire RS 485 for Modbus			
Transmission Frame	RTU for Modbus			
Transmission Rate	4800 bps, 9600 bps, 19200 bps, 38.4 Kbps for Modbus on terminal			
	9600 bps, 19200 bps for Modbus on front face 20 kbps, 50 kbps, 125 kbps, 250 kbps, 500 kbps, 1 Mbps for CANopen			
Data Farmat				
Data Format	bits, 1 stop, even parity for Modbus on front face bits, odd even or no configurable parity for Modbus on terminal			
	No impedance for Modbus			
Type Of Polarization	·			
	1247 for CANopen			
	·			
Number Of Addresses	1247 for CANopen			
Number Of Addresses Method Of Access	1247 for CANopen 1247 for Modbus Slave CANopen Communication card for CC-Link			
Number Of Addresses Method Of Access	1247 for CANopen 1247 for Modbus Slave CANopen			
Number Of Addresses Method Of Access	1247 for CANopen 1247 for Modbus Slave CANopen Communication card for CC-Link			
Number Of Addresses Method Of Access	1247 for CANopen 1247 for Modbus Slave CANopen Communication card for CC-Link Communication card for DeviceNet Communication card for EtherNet/IP Communication card for Fipio			
Number Of Addresses Method Of Access	1247 for CANopen 1247 for Modbus Slave CANopen Communication card for CC-Link Communication card for DeviceNet Communication card for EtherNet/IP Communication card for Fipio Communication card for Interbus-S			
Number Of Addresses Method Of Access	1247 for CANopen 1247 for Modbus Slave CANopen Communication card for CC-Link Communication card for DeviceNet Communication card for EtherNet/IP Communication card for Fipio Communication card for Interbus-S Communication card for Modbus Plus			
Number Of Addresses Method Of Access	1247 for CANopen 1247 for Modbus Slave CANopen Communication card for CC-Link Communication card for DeviceNet Communication card for EtherNet/IP Communication card for Fipio Communication card for Interbus-S Communication card for Modbus Plus Communication card for Modbus/Uni-Telway			
Number Of Addresses Method Of Access	1247 for CANopen 1247 for Modbus Slave CANopen Communication card for CC-Link Communication card for DeviceNet Communication card for EtherNet/IP Communication card for Fipio Communication card for Interbus-S Communication card for Modbus Plus Communication card for Modbus/Uni-Telway Communication card for Profibus DP			
Type Of Polarization Number Of Addresses Method Of Access Option Card	1247 for CANopen 1247 for Modbus Slave CANopen Communication card for CC-Link Communication card for DeviceNet Communication card for EtherNet/IP Communication card for Fipio Communication card for Interbus-S Communication card for Modbus Plus Communication card for Modbus/Uni-Telway Communication card for Profibus DP Communication card for Profibus DP			
Number Of Addresses Method Of Access	1247 for CANopen 1247 for Modbus Slave CANopen Communication card for CC-Link Communication card for DeviceNet Communication card for EtherNet/IP Communication card for Fipio Communication card for Interbus-S Communication card for Modbus Plus Communication card for Modbus/Uni-Telway Communication card for Profibus DP Communication card for Profibus DP V1 Communication card for Modbus TCP/IP			
Number Of Addresses Method Of Access	1247 for CANopen 1247 for Modbus Slave CANopen Communication card for CC-Link Communication card for DeviceNet Communication card for EtherNet/IP Communication card for Fipio Communication card for Interbus-S Communication card for Modbus Plus Communication card for Modbus/Uni-Telway Communication card for Profibus DP Communication card for Profibus DP V1 Communication card for Modbus TCP/IP Controller inside programmable card			
Number Of Addresses Method Of Access	1247 for CANopen 1247 for Modbus Slave CANopen Communication card for CC-Link Communication card for DeviceNet Communication card for EtherNet/IP Communication card for Fipio Communication card for Interbus-S Communication card for Modbus Plus Communication card for Modbus/Uni-Telway Communication card for Profibus DP Communication card for Profibus DP V1 Communication card for Modbus TCP/IP			

Options For Enclosure	Safe standstill for power circuit
Configuration	PTC relay for power circuit
	Pt100 relay for power circuit
	Insulation monitoring for power circuit
	Design for IT networks for power circuit
	External 230 V supply terminals for power circuit
	Buffer voltage 24 V DC power supply for power circuit
	External 24 V DC supply terminals for power circuit
	Enclosure lighting for power circuit
	Key switch (local/remote) for power circuit Motor heating for power circuit
	External motor fan for power circuit
	Voltmeter for power circuit
	Door handle for main switch for power circuit
	Circuit breaker for power circuit
	Line contactor for power circuit
	Ammeter for power circuit
	Enclosure heating for power circuit
	Motor choke for power circuit
	Cable entry via the top for power circuit
	Enclosure plinth for power circuit
	Braking unit for power circuit
	Door handle for circuit breaker for power circuit
	Control terminals for control circuit
	Adaptor for 115 V logic inputs for control circuit
	Relay output C/O for control circuit
	Isolated amplifier for control circuit
Operating Position	Vertical +/- 10 degree
Colour Of Enclosure	Light grey (RAL 7035)
Height	2262 mm
Width	1000 mm
Depth	642 mm
Net Weight	660 kg
	1 2/50 us - 8/20 us surge immunity test level 3 conforming to IEC 61000-4-5
Environment Electromagnetic Compatibility	1.2/50 μs - 8/20 μs surge immunity test level 3 conforming to IEC 61000-4-5 Conducted radio-frequency immunity test level 3 conforming to IEC 61000-4-6 Electrical fast transient/burst immunity test level 4 conforming to IEC 61000-4-4 Electrostatic discharge immunity test level 3 conforming to IEC 61000-4-2
	Conducted radio-frequency immunity test level 3 conforming to IEC 61000-4-6 Electrical fast transient/burst immunity test level 4 conforming to IEC 61000-4-4
	Conducted radio-frequency immunity test level 3 conforming to IEC 61000-4-6 Electrical fast transient/burst immunity test level 4 conforming to IEC 61000-4-4 Electrostatic discharge immunity test level 3 conforming to IEC 61000-4-2 Radiated radio-frequency electromagnetic field immunity test level 3 conforming to IEC 61000-4-3
	Conducted radio-frequency immunity test level 3 conforming to IEC 61000-4-6 Electrical fast transient/burst immunity test level 4 conforming to IEC 61000-4-4 Electrostatic discharge immunity test level 3 conforming to IEC 61000-4-2 Radiated radio-frequency electromagnetic field immunity test level 3 conforming to
Electromagnetic Compatibility	Conducted radio-frequency immunity test level 3 conforming to IEC 61000-4-6 Electrical fast transient/burst immunity test level 4 conforming to IEC 61000-4-4 Electrostatic discharge immunity test level 3 conforming to IEC 61000-4-2 Radiated radio-frequency electromagnetic field immunity test level 3 conforming to IEC 61000-4-3
	Conducted radio-frequency immunity test level 3 conforming to IEC 61000-4-6 Electrical fast transient/burst immunity test level 4 conforming to IEC 61000-4-4 Electrostatic discharge immunity test level 3 conforming to IEC 61000-4-2 Radiated radio-frequency electromagnetic field immunity test level 3 conforming to IEC 61000-4-3 Voltage dips and interruptions immunity test conforming to IEC 61000-4-11
Electromagnetic Compatibility Pollution Degree	Conducted radio-frequency immunity test level 3 conforming to IEC 61000-4-6 Electrical fast transient/burst immunity test level 4 conforming to IEC 61000-4-4 Electrostatic discharge immunity test level 3 conforming to IEC 61000-4-2 Radiated radio-frequency electromagnetic field immunity test level 3 conforming to IEC 61000-4-3 Voltage dips and interruptions immunity test conforming to IEC 61000-4-11 3 conforming to EN/IEC 61800-5-1
Electromagnetic Compatibility Pollution Degree Ip Degree Of Protection	Conducted radio-frequency immunity test level 3 conforming to IEC 61000-4-6 Electrical fast transient/burst immunity test level 4 conforming to IEC 61000-4-4 Electrostatic discharge immunity test level 3 conforming to IEC 61000-4-2 Radiated radio-frequency electromagnetic field immunity test level 3 conforming to IEC 61000-4-3 Voltage dips and interruptions immunity test conforming to IEC 61000-4-11 3 conforming to EN/IEC 61800-5-1 IP54 0.6 gn (f= 10200 Hz) conforming to EN/IEC 60068-2-6
Electromagnetic Compatibility Pollution Degree Ip Degree Of Protection	Conducted radio-frequency immunity test level 3 conforming to IEC 61000-4-6 Electrical fast transient/burst immunity test level 4 conforming to IEC 61000-4-4 Electrostatic discharge immunity test level 3 conforming to IEC 61000-4-2 Radiated radio-frequency electromagnetic field immunity test level 3 conforming to IEC 61000-4-3 Voltage dips and interruptions immunity test conforming to IEC 61000-4-11 3 conforming to EN/IEC 61800-5-1
Electromagnetic Compatibility Pollution Degree Ip Degree Of Protection	Conducted radio-frequency immunity test level 3 conforming to IEC 61000-4-6 Electrical fast transient/burst immunity test level 4 conforming to IEC 61000-4-4 Electrostatic discharge immunity test level 3 conforming to IEC 61000-4-2 Radiated radio-frequency electromagnetic field immunity test level 3 conforming to IEC 61000-4-3 Voltage dips and interruptions immunity test conforming to IEC 61000-4-11 3 conforming to EN/IEC 61800-5-1 IP54 0.6 gn (f= 10200 Hz) conforming to EN/IEC 60068-2-6 1.5 mm (f= 310 Hz) conforming to EN/IEC 60068-2-6
Electromagnetic Compatibility Pollution Degree Ip Degree Of Protection	Conducted radio-frequency immunity test level 3 conforming to IEC 61000-4-6 Electrical fast transient/burst immunity test level 4 conforming to IEC 61000-4-4 Electrostatic discharge immunity test level 3 conforming to IEC 61000-4-2 Radiated radio-frequency electromagnetic field immunity test level 3 conforming to IEC 61000-4-3 Voltage dips and interruptions immunity test conforming to IEC 61000-4-11 3 conforming to EN/IEC 61800-5-1 IP54 0.6 gn (f= 10200 Hz) conforming to EN/IEC 60068-2-6 1.5 mm (f= 310 Hz) conforming to EN/IEC 60068-2-6
Pollution Degree Ip Degree Of Protection Vibration Resistance	Conducted radio-frequency immunity test level 3 conforming to IEC 61000-4-6 Electrical fast transient/burst immunity test level 4 conforming to IEC 61000-4-4 Electrostatic discharge immunity test level 3 conforming to IEC 61000-4-2 Radiated radio-frequency electromagnetic field immunity test level 3 conforming to IEC 61000-4-3 Voltage dips and interruptions immunity test conforming to IEC 61000-4-11 3 conforming to EN/IEC 61800-5-1 IP54 0.6 gn (f= 10200 Hz) conforming to EN/IEC 60068-2-6 1.5 mm (f= 310 Hz) conforming to EN/IEC 60068-2-6 3M3 conforming to EN/IEC 60721-3-3 4 gn for 11 ms conforming to EN/IEC 60068-2-27
Pollution Degree Ip Degree Of Protection Vibration Resistance Shock Resistance	Conducted radio-frequency immunity test level 3 conforming to IEC 61000-4-6 Electrical fast transient/burst immunity test level 4 conforming to IEC 61000-4-4 Electrostatic discharge immunity test level 3 conforming to IEC 61000-4-2 Radiated radio-frequency electromagnetic field immunity test level 3 conforming to IEC 61000-4-3 Voltage dips and interruptions immunity test conforming to IEC 61000-4-11 3 conforming to EN/IEC 61800-5-1 IP54 0.6 gn (f= 10200 Hz) conforming to EN/IEC 60068-2-6 1.5 mm (f= 310 Hz) conforming to EN/IEC 60068-2-6 3M3 conforming to EN/IEC 60721-3-3 4 gn for 11 ms conforming to EN/IEC 60068-2-27 3M2 conforming to EN/IEC 60721-3-3
Pollution Degree Ip Degree Of Protection Vibration Resistance Shock Resistance	Conducted radio-frequency immunity test level 3 conforming to IEC 61000-4-6 Electrical fast transient/burst immunity test level 4 conforming to IEC 61000-4-4 Electrostatic discharge immunity test level 3 conforming to IEC 61000-4-2 Radiated radio-frequency electromagnetic field immunity test level 3 conforming to IEC 61000-4-3 Voltage dips and interruptions immunity test conforming to IEC 61000-4-11 3 conforming to EN/IEC 61800-5-1 IP54 0.6 gn (f= 10200 Hz) conforming to EN/IEC 60068-2-6 1.5 mm (f= 310 Hz) conforming to EN/IEC 60068-2-6 3M3 conforming to EN/IEC 60721-3-3 4 gn for 11 ms conforming to EN/IEC 60068-2-27 3M2 conforming to EN/IEC 60721-3-3 78 dB conforming to 86/188/EEC Without condensation: 3C2 conforming to IEC 60721-3-3
Pollution Degree Ip Degree Of Protection Vibration Resistance Shock Resistance	Conducted radio-frequency immunity test level 3 conforming to IEC 61000-4-6 Electrical fast transient/burst immunity test level 4 conforming to IEC 61000-4-4 Electrostatic discharge immunity test level 3 conforming to IEC 61000-4-2 Radiated radio-frequency electromagnetic field immunity test level 3 conforming to IEC 61000-4-3 Voltage dips and interruptions immunity test conforming to IEC 61000-4-11 3 conforming to EN/IEC 61800-5-1 IP54 0.6 gn (f= 10200 Hz) conforming to EN/IEC 60068-2-6 1.5 mm (f= 310 Hz) conforming to EN/IEC 60068-2-6 3M3 conforming to EN/IEC 60721-3-3 4 gn for 11 ms conforming to EN/IEC 60068-2-27 3M2 conforming to EN/IEC 60721-3-3
Pollution Degree Ip Degree Of Protection Vibration Resistance Shock Resistance Noise Level Environmental Characteristic	Conducted radio-frequency immunity test level 3 conforming to IEC 61000-4-6 Electrical fast transient/burst immunity test level 4 conforming to IEC 61000-4-4 Electrostatic discharge immunity test level 3 conforming to IEC 61000-4-2 Radiated radio-frequency electromagnetic field immunity test level 3 conforming to IEC 61000-4-3 Voltage dips and interruptions immunity test conforming to IEC 61000-4-11 3 conforming to EN/IEC 61800-5-1 IP54 0.6 gn (f= 10200 Hz) conforming to EN/IEC 60068-2-6 1.5 mm (f= 310 Hz) conforming to EN/IEC 60068-2-6 3M3 conforming to EN/IEC 60721-3-3 4 gn for 11 ms conforming to EN/IEC 60068-2-27 3M2 conforming to EN/IEC 60721-3-3 Without condensation: 3C2 conforming to IEC 60721-3-3 Without condensation: 3K3 conforming to IEC 60721-3-3 Without condensation: 3S2 conforming to IEC 60721-3-3 Without condensation: 3S2 conforming to IEC 60721-3-3
Pollution Degree Ip Degree Of Protection Vibration Resistance Shock Resistance	Conducted radio-frequency immunity test level 3 conforming to IEC 61000-4-6 Electrical fast transient/burst immunity test level 4 conforming to IEC 61000-4-4 Electrostatic discharge immunity test level 3 conforming to IEC 61000-4-2 Radiated radio-frequency electromagnetic field immunity test level 3 conforming to IEC 61000-4-3 Voltage dips and interruptions immunity test conforming to IEC 61000-4-11 3 conforming to EN/IEC 61800-5-1 IP54 0.6 gn (f= 10200 Hz) conforming to EN/IEC 60068-2-6 1.5 mm (f= 310 Hz) conforming to EN/IEC 60068-2-6 3M3 conforming to EN/IEC 60721-3-3 4 gn for 11 ms conforming to EN/IEC 60068-2-27 3M2 conforming to EN/IEC 60721-3-3 78 dB conforming to 86/188/EEC Without condensation: 3C2 conforming to IEC 60721-3-3 Without condensation: 3K3 conforming to IEC 60721-3-3
Pollution Degree Ip Degree Of Protection Vibration Resistance Shock Resistance Noise Level Environmental Characteristic Relative Humidity Ambient Air Temperature For	Conducted radio-frequency immunity test level 3 conforming to IEC 61000-4-6 Electrical fast transient/burst immunity test level 4 conforming to IEC 61000-4-4 Electrostatic discharge immunity test level 3 conforming to IEC 61000-4-2 Radiated radio-frequency electromagnetic field immunity test level 3 conforming to IEC 61000-4-3 Voltage dips and interruptions immunity test conforming to IEC 61000-4-11 3 conforming to EN/IEC 61800-5-1 IP54 0.6 gn (f= 10200 Hz) conforming to EN/IEC 60068-2-6 1.5 mm (f= 310 Hz) conforming to EN/IEC 60068-2-6 3M3 conforming to EN/IEC 60721-3-3 4 gn for 11 ms conforming to EN/IEC 60068-2-27 3M2 conforming to EN/IEC 60721-3-3 Without condensation: 3C2 conforming to IEC 60721-3-3 Without condensation: 3K3 conforming to IEC 60721-3-3 Without condensation: 3S2 conforming to IEC 60721-3-3 Without condensation: 3S2 conforming to IEC 60721-3-3
Pollution Degree Ip Degree Of Protection Vibration Resistance Shock Resistance Noise Level Environmental Characteristic Relative Humidity	Conducted radio-frequency immunity test level 3 conforming to IEC 61000-4-6 Electrical fast transient/burst immunity test level 4 conforming to IEC 61000-4-4 Electrostatic discharge immunity test level 3 conforming to IEC 61000-4-2 Radiated radio-frequency electromagnetic field immunity test level 3 conforming to IEC 61000-4-3 Voltage dips and interruptions immunity test conforming to IEC 61000-4-11 3 conforming to EN/IEC 61800-5-1 IP54 0.6 gn (f= 10200 Hz) conforming to EN/IEC 60068-2-6 1.5 mm (f= 310 Hz) conforming to EN/IEC 60068-2-6 3M3 conforming to EN/IEC 60721-3-3 4 gn for 11 ms conforming to EN/IEC 60068-2-27 3M2 conforming to EN/IEC 60721-3-3 78 dB conforming to 86/188/EEC Without condensation: 3C2 conforming to IEC 60721-3-3 Without condensation: 3K3 conforming to IEC 60721-3-3 Without condensation: 3S2 conforming to IEC 60721-3-3 Without condensation: 3S2 conforming to IEC 60721-3-3
Pollution Degree Ip Degree Of Protection Vibration Resistance Shock Resistance Noise Level Environmental Characteristic Relative Humidity Ambient Air Temperature For Operation	Conducted radio-frequency immunity test level 3 conforming to IEC 61000-4-6 Electrical fast transient/burst immunity test level 4 conforming to IEC 61000-4-4 Electrostatic discharge immunity test level 3 conforming to IEC 61000-4-2 Radiated radio-frequency electromagnetic field immunity test level 3 conforming to IEC 61000-4-3 Voltage dips and interruptions immunity test conforming to IEC 61000-4-11 3 conforming to EN/IEC 61800-5-1 IP54 0.6 gn (f= 10200 Hz) conforming to EN/IEC 60068-2-6 1.5 mm (f= 310 Hz) conforming to EN/IEC 60068-2-6 3M3 conforming to EN/IEC 60721-3-3 4 gn for 11 ms conforming to EN/IEC 60068-2-27 3M2 conforming to EN/IEC 60721-3-3 78 dB conforming to 86/188/EEC Without condensation: 3C2 conforming to IEC 60721-3-3 Without condensation: 3K3 conforming to IEC 60721-3-3 Without condensation: 3S2 conforming to IEC 60721-3-3 095 % 040 °C (without derating) 4050 °C (with current derating of 1.2 % per °C)
Pollution Degree Ip Degree Of Protection Vibration Resistance Shock Resistance Noise Level Environmental Characteristic Relative Humidity Ambient Air Temperature For	Conducted radio-frequency immunity test level 3 conforming to IEC 61000-4-6 Electrical fast transient/burst immunity test level 4 conforming to IEC 61000-4-4 Electrostatic discharge immunity test level 3 conforming to IEC 61000-4-2 Radiated radio-frequency electromagnetic field immunity test level 3 conforming to IEC 61000-4-3 Voltage dips and interruptions immunity test conforming to IEC 61000-4-11 3 conforming to EN/IEC 61800-5-1 IP54 0.6 gn (f= 10200 Hz) conforming to EN/IEC 60068-2-6 1.5 mm (f= 310 Hz) conforming to EN/IEC 60068-2-6 3M3 conforming to EN/IEC 60721-3-3 4 gn for 11 ms conforming to EN/IEC 60068-2-27 3M2 conforming to EN/IEC 60721-3-3 Without condensation: 3C2 conforming to IEC 60721-3-3 Without condensation: 3K3 conforming to IEC 60721-3-3 Without condensation: 3S2 conforming to IEC 60721-3-3 O95 % 040 °C (without derating)

<= 1000 m without derating 1000...3000 m with current derating 1 % per 100 m

1800 m3/h

Volume Of Cooling Air

Operating Altitude

Standards	EN 55011 class A group 2 EN 61800-3 environments 2 category C3 EN/IEC 61800-3 EN 61800-3 environments 1 category C3 EN/IEC 61800-5-1
Product Certifications	GOST ATEX
Marking	CE

Packing Units

Unit Type Of Package 1	PCE
	. 32
Number Of Units In Package 1	1
Package 1 Height	216.0 cm
Package 1 Width	66.0 cm
Package 1 Length	101.6 cm
Package 1 Weight	660.0 kg


Contractual warranty

Warranty 18 months


Dimensions Drawings

IP 54 Floor-Standing Enclosure Compact Version

Standard Compact Floor-Standing Enclosure



Standard Compact Floor-Standing Enclosure + Additional Floor-Standing Enclosures, According to the Configuration



- (1) Seal. For each floor-standing enclosure added, allow a 4 mm/0.15 in. space for the seal.
- (2) Standard IP 54 compact version floor-standing enclosure.

NOTE: The position of the enclosures must be complied with during installation. The number of additional enclosures can vary according to the chosen configuration.

Product datasheet

ATV71EXC5C31N4

Options	а	a1	a2	a3	a4
With or without common options or options (3) dependent on the drive rating	1016 mm/ 40 in.	_	_	-	1016 mm/ 40 in.
Cable entry via the top option (4)	1000 mm/ 39.3 in.	_	408 mm/ 16 in.	408 mm/ 16 in.	1824 mm/ 71.8 in.
Braking unit option only and/or options (3) dependent on rating	1008 mm/ 39.6 in.	-	408 mm/ 16 in.	_	1420 mm/ 55.9 in.
Braking unit + cable entry via the top options (4)	1000 mm/ 39.3 in.	408 mm/ 16 in.	400 mm/ 15.7 in.	408 mm/ 16 in.	2228 mm/ 87.7 in.
Motor choke option	1008 mm/ 39.6 in.	-	_	408 mm/ 16 in.	1420 mm/ 55.9 in.
Sinus filter option	1008 mm/ 39.6 in.	-	-	608 mm/ 23.9 in.	1620 mm/ 63.7 in.

⁽³⁾ Except sinus filter option, which requires an additional enclosure. The sinus filter option is not compatible with the cable entry via the top option.


⁽⁴⁾ The cable entry via the top option is not compatible with the sinus filter option.

ATV71EXC5C31N4

Connections and Schema

Floor-Standing Enclosure Compact Version

Wiring Diagram



- A1 Drive
- A2 Enclosure
- F1 Fast-acting semi-conductor fuse
- IL1 Line choke
- Q1 Switch
- (1) Fault relay contacts. For remote signalling of drive status.

Product datasheet ATV71EXC5C31N4


Performance Curves

Ready to Use IP 54 Enclosure

Derating Curves

The derating curves for the drive nominal current (In) are dependent on the temperature and switching frequency. For intermediate temperatures, interpolate between 2 curves.

NOTE: The drive will reduce the switching frequency automatically in the event of excessive temperature rise.



X Switching frequency (kHz)

NOTE: The temperatures shown correspond to the temperature of the air entering the enclosure.